



CITY OF NORTHAMPTON, MASSACHUSETTS
DEPARTMENT OF PUBLIC WORKS
125 Locust Street
Northampton, MA 01060

413-587-1570
Fax 413-587-1576

Edward Huntley, P.E.
Director, City Engineer

Memorandum

To: Ned Huntley
From: Felix Harvey
Date: December 11, 2015
Re: Pole Petition #18441465 (South Main Street, across from Hinckley St Ext.)

Ned:

I have reviewed DPW records and visited the site to view the proposed pole location. The proposed location as depicted in the application and identified by a stake is unacceptable due to its proximity to a Drainage system located there. I have prepared a sketch (attached) showing two alternative locations that would be acceptable based on setback requirements from the drainage system (10 feet from the Drain Manhole (DMH) and 5' from the drain pipe).

Based on this information, I believe that the request may be approved with conditions of the above set-back refrom the drainage system requirements stated above and shown on the attached sketch.

Approved BH
12/11/15

